

## School Environmental Health &amp; Safety Inspection Form

School VALLEY VIEW INTERMEDIATE				Date of Inspection Tuesday, September 22, 2015				
Address 64 COMSTOCK				Type of Inspection <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Consultation <input type="checkbox"/> Follow-up				
City GERMANTOWN OH			Zip 45327	School Classification <input checked="" type="checkbox"/> Public <input type="checkbox"/> Non-Public				
County Montgomery County Ohio			Phone	Type of School (Check all that apply) <input type="checkbox"/> Preschool <input checked="" type="checkbox"/> Middle <input type="checkbox"/> High <input type="checkbox"/> Kindergarten <input checked="" type="checkbox"/> Intermediate <input type="checkbox"/> Career Center <input type="checkbox"/> Elementary    Other				
Principal or Chief Building Administrator HAROLD BOWMAN								
Grades of Instruction 3-6			Regular hours of school operation 7A.M.-4:00 P.M.		HVAC System (Check all that apply)		HEATING	COOLING
Enrollment 526	Classrooms 31	Year Constructed 01/01/1922	Year(s) Renovated		Central forced Air Systems	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					Unit Ventilators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					Steam/Hot Water Radiators	<input checked="" type="checkbox"/>		n/a
					Electric Heating Units	<input type="checkbox"/>		n/a
					Geothermal	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					Other			
School District VALLEYVIEW								


## Indicate areas of deficiency by marking appropriate box (OAC 3701-54-)

<input type="checkbox"/> 06-A1 Grounds & Building Exterior	<input type="checkbox"/> 08-C Industrial Arts Classrooms	<input type="checkbox"/> 09-E Training or Weight Lifting Rooms
<input type="checkbox"/> 06-A2 Playgrounds	<input type="checkbox"/> 08-D Stage & Set Design Areas	<input type="checkbox"/> 09-F Restrooms
<input type="checkbox"/> 06-A3 Solid Waste Disposal Areas	<input type="checkbox"/> 08-E Music Room(s)	<input type="checkbox"/> 09-G Custodial Closets
<input type="checkbox"/> 06-A4 Outdoor Athletic Facilities	<input type="checkbox"/> 08-F Family & Consumer Science	<input type="checkbox"/> 09-H Mechanical Rooms
<input type="checkbox"/> 07-A All School Indoor Environments	<input type="checkbox"/> 09-A Auditoriums & Student Dining	<input type="checkbox"/> 09-I Attics/Mezzanines/Crawls
<input type="checkbox"/> 07-B Hallways & Stairwells	<input type="checkbox"/> 09-B Library/Media Center	<input type="checkbox"/> 09-J Water, Wastewater System
<input type="checkbox"/> 08-A Science Classrooms	<input type="checkbox"/> 09-C Indoor Athletic Facilities	<input type="checkbox"/> 09-K Health Care Areas
<input type="checkbox"/> 08-B Visual Arts Classrooms	<input type="checkbox"/> 09-D Locker Rooms	<input type="checkbox"/> 09-L/M Admin Areas/Rules&Protocols

Rule No. Location	Observations and recommendations for change, if adverse conditions exists.
----------------------	--

Some drinking fountains in facility do not have flowing water cresting over the mouth guard. Maintenance is aware of this issue and will correct it before the next inspection.

Over all school sanitation is satisfactory.

Inspected by Joshua R Lucas		Health District Public Health Dayton & Montgomery County		Name of School Staff Accompanying Inspector	
Signature 		Date 9/22/15	R.S./SIT # Registered Sanitarian #3640		Phone PH-DMC 937-496-3128
Received by		Date	Title		Phone

School Environmental Health & Safety Inspection Form

School VALLEY VIEW PRIMARY				Date of Inspection Tuesday, September 22, 2015			
Address 110 COMSTOCK				Type of Inspection <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Consultation <input type="checkbox"/> Follow-up			
City DAYTON OH			Zip 45327	School Classification <input checked="" type="checkbox"/> Public <input type="checkbox"/> Non-Public			
County Montgomery County Ohio			Phone	Type of School (Check all that apply) <input type="checkbox"/> Preschool <input type="checkbox"/> Middle <input type="checkbox"/> High <input type="checkbox"/> Kindergarten <input type="checkbox"/> Intermediate <input type="checkbox"/> Career Center <input checked="" type="checkbox"/> Elementary   Other			
Principal or Chief Building Administrator BILL LAUSON							
Grades of Instruction K-5		Regular hours of school operation 9:10A.M-3:30 P.M.		HVAC System (Check all that apply)		HEATING	COOLING
Enrollment 496		Classrooms 32	Year Constructed 01/01/1954	Year(s) Renovated	Central forced Air Systems	<input type="checkbox"/>	<input type="checkbox"/>
School District VALLEYVIEW				Unit Ventilators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				Steam/Hot Water Radiators	<input checked="" type="checkbox"/>	n/a	n/a
				Electric Heating Units	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				Geothermal	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				Other			

Indicate areas of deficiency by marking appropriate box (OAC 3701-54-)

<input type="checkbox"/> 06-A1 Grounds & Building Exterior	<input type="checkbox"/> 08-C Industrial Arts Classrooms	<input type="checkbox"/> 09-E Training or Weight Lifting Rooms
<input type="checkbox"/> 06-A2 Playgrounds	<input type="checkbox"/> 08-D Stage & Set Design Areas	<input type="checkbox"/> 09-F Restrooms
<input type="checkbox"/> 06-A3 Solid Waste Disposal Areas	<input type="checkbox"/> 08-E Music Room(s)	<input type="checkbox"/> 09-G Custodial Closets
<input type="checkbox"/> 06-A4 Outdoor Athletic Facilities	<input type="checkbox"/> 08-F Family & Consumer Science	<input type="checkbox"/> 09-H Mechanical Rooms
<input type="checkbox"/> 07-A All School Indoor Environments	<input type="checkbox"/> 09-A Auditoriums & Student Dining	<input type="checkbox"/> 09-I Attics/Mezzanines/Crawls
<input type="checkbox"/> 07-B Hallways & Stairwells	<input type="checkbox"/> 09-B Library/Media Center	<input type="checkbox"/> 09-J Water, Wastewater System
<input type="checkbox"/> 08-A Science Classrooms	<input type="checkbox"/> 09-C Indoor Athletic Facilities	<input type="checkbox"/> 09-K Health Care Areas
<input type="checkbox"/> 08-B Visual Arts Classrooms	<input type="checkbox"/> 09-D Locker Rooms	<input type="checkbox"/> 09-L/M Admin Areas/Rules & Protocols

Rule No. Location	Observations and recommendations for change, if adverse conditions exists.
-------------------	--

-Some handwashing have low hot water pressure. Maintenance is aware of this issue and will have it corrected before the next school inspection.  
Overall school sanitation is satisfactory.

Inspected by Joshua R Lucas		Health District Public Health Dayton & Montgomery County		Name of School Staff Accompanying Inspector DAVE ESHBAUGH	
Signature <i>Joshua R. Lucas</i>	Date 9/22/15	R.S./SIT # Registered Sanitarian #3840	Phone PH-DMC 937-496-3128		
Received by <i>X D. 22</i>	Date 9/22/15	Title <i>X Maint. Supervisor</i>	Phone <i>(937) 313-4784</i>		

## School Environmental Health &amp; Safety Inspection Form


School VALLEY VIEW HIGH SCHOOL				Date of Inspection Thursday, September 24, 2015		
Address 6027 FARMERSVILLE RD				Type of Inspection <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Consultation <input type="checkbox"/> Follow-up		
City FARMERSVILLE OH		Zip 45327		School Classification <input checked="" type="checkbox"/> Public <input type="checkbox"/> Non-Public		
County Montgomery County Ohio			Phone	Type of School (Check all that apply) <input type="checkbox"/> Preschool <input type="checkbox"/> Middle <input checked="" type="checkbox"/> High <input type="checkbox"/> Kindergarten <input type="checkbox"/> Intermediate <input type="checkbox"/> Career Center <input type="checkbox"/> Elementary    Other		
Principal or Chief Building Administrator TODD KOZAREC				HVAC System (Check all that apply)		
Grades of Instruction 9-12		Regular hours of school operation 7:45A.M.-2:30P.M.		HEATING	COOLING	
Enrollment 540	Classrooms 30	Year Constructed 01/19/1968	Year(s) Renovated	Central forced Air Systems	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				Unit Ventilators	<input type="checkbox"/>	<input type="checkbox"/>
				Steam/Hot Water Radiators	<input checked="" type="checkbox"/>	n/a
				Electric Heating Units	<input type="checkbox"/>	n/a
				Geothermal	<input type="checkbox"/>	<input type="checkbox"/>
				Other		
School District VALLEYVIEW SCHOOL DISTRICT						

## Indicate areas of deficiency by marking appropriate box (OAC 3701-54-)

<input type="checkbox"/> 06-A1 Grounds & Building Exterior	<input type="checkbox"/> 08-C Industrial Arts Classrooms	<input type="checkbox"/> 09-E Training or Weight Lifting Rooms
<input type="checkbox"/> 06-A2 Playgrounds	<input type="checkbox"/> 08-D Stage & Set Design Areas	<input type="checkbox"/> 09-F Restrooms
<input type="checkbox"/> 06-A3 Solid Waste Disposal Areas	<input type="checkbox"/> 08-E Music Room(s)	<input type="checkbox"/> 09-G Custodial Closets
<input type="checkbox"/> 06-A4 Outdoor Athletic Facilities	<input type="checkbox"/> 08-F Family & Consumer Science	<input type="checkbox"/> 09-H Mechanical Rooms
<input type="checkbox"/> 07-A All School Indoor Environments	<input type="checkbox"/> 09-A Auditoriums & Student Dining	<input type="checkbox"/> 09-I Attics/Mezzanines/Crawls
<input type="checkbox"/> 07-B Hallways & Stairwells	<input type="checkbox"/> 09-B Library/Media Center	<input type="checkbox"/> 09-J Water, Wastewater System
<input type="checkbox"/> 08-A Science Classrooms	<input type="checkbox"/> 09-C Indoor Athletic Facilities	<input type="checkbox"/> 09-K Health Care Areas
<input type="checkbox"/> 08-B Visual Arts Classrooms	<input type="checkbox"/> 09-D Locker Rooms	<input type="checkbox"/> 09-L/M Admin Areas/Rules & Protocols

Rule No. Location	Observations and recommendations for change, if adverse conditions exists.
----------------------	--

- Accumulation of moisture is noticed in the boys and girls locker room shower areas. Clean shower areas to prevent the growth of mold/fungus.
- Some chemicals are inappropriately stored where students can have access to them. All chemicals shall be stored so students do not have access to them and to prevent potential injury.

Inspected by Joshua R Lucas		Health District Public Health Dayton & Montgomery County		Name of School Staff Accompanying Inspector ERIC DEPEW	
Signature 		Date 9/24/2015	R.S./SIT # Registered Sanitarian #3640		Phone PH-DMC 937-496-3128
Received by		Date	Title		Phone

## School Environmental Health &amp; Safety Inspection Form


School VALLEY VIEW JUNIOR HIGH SCHOOL				Date of Inspection Thursday, September 24, 2015		
Address 202 JACKSON STREET				Type of Inspection <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Consultation <input type="checkbox"/> Follow-up		
City DAYTON OH		Zip 45325		School Classification <input checked="" type="checkbox"/> Public <input type="checkbox"/> Non-Public		
County Montgomery County Ohio		Phone		Type of School (Check all that apply) <input type="checkbox"/> Preschool <input type="checkbox"/> Middle <input type="checkbox"/> High <input type="checkbox"/> Kindergarten <input type="checkbox"/> Intermediate <input type="checkbox"/> Career Center <input checked="" type="checkbox"/> Elementary    Other		
Principal or Chief Building Administrator NICHOLE THOMAS				HVAC System (Check all that apply)		
Grades of Instruction 7-8		Regular hours of school operation 9A.M.-3:15P.M.		HEATING		COOLING
Enrollment 298		Classrooms 25	Year Constructed 01/01/1923	Year(s) Renovated 01/01/1955	Central forced Air Systems <input type="checkbox"/>	<input type="checkbox"/>
School District VALLEYVIEW				Unit Ventilators	<input type="checkbox"/>	<input type="checkbox"/>
				Steam/Hot Water Radiators	<input checked="" type="checkbox"/>	n/a
				Electric Heating Units	<input type="checkbox"/>	n/a
				Geothermal	<input type="checkbox"/>	<input type="checkbox"/>
				Other		

## Indicate areas of deficiency by marking appropriate box (OAC 3701-54-)

<input type="checkbox"/> 06-A1 Grounds & Building Exterior	<input type="checkbox"/> 08-C Industrial Arts Classrooms	<input type="checkbox"/> 09-E Training or Weight Lifting Rooms
<input type="checkbox"/> 06-A2 Playgrounds	<input type="checkbox"/> 08-D Stage & Set Design Areas	<input type="checkbox"/> 09-F Restrooms
<input type="checkbox"/> 06-A3 Solid Waste Disposal Areas	<input type="checkbox"/> 08-E Music Room(s)	<input type="checkbox"/> 09-G Custodial Closets
<input type="checkbox"/> 06-A4 Outdoor Athletic Facilities	<input type="checkbox"/> 08-F Family & Consumer Science	<input type="checkbox"/> 09-H Mechanical Rooms
<input type="checkbox"/> 07-A All School Indoor Environments	<input type="checkbox"/> 09-A Auditoriums & Student Dining	<input type="checkbox"/> 09-I Attics/Mezzanines/Crawls
<input type="checkbox"/> 07-B Hallways & Stairwells	<input type="checkbox"/> 09-B Library/Media Center	<input type="checkbox"/> 09-J Water, Wastewater System
<input type="checkbox"/> 08-A Science Classrooms	<input type="checkbox"/> 09-C Indoor Athletic Facilities	<input type="checkbox"/> 09-K Health Care Areas
<input type="checkbox"/> 08-B Visual Arts Classrooms	<input type="checkbox"/> 09-D Locker Rooms	<input type="checkbox"/> 09-L/M Admin Areas/Rules&Protocols

Rule No. Location	Observations and recommendations for change, if adverse conditions exists.
----------------------	--

- Chemicals are left out classrooms. All chemicals shall be stored so students do not have access to them and to prevent potential injury.
- Tempered water is not provided to some handwashing sinks in the building. All handwashing sinks shall provide tempered water for proper hand washing to occur.

Inspected by Joshua R Lucas		Health District Public Health Dayton & Montgomery County		Name of School Staff Accompanying Inspector ERIC DEPEW	
Signature 		Date 9/24/2015	R.S./SIT # Registered Sanitarian #3640		Phone PH-DMC 937-496-3128
Received by		Date	Title		Phone